

City of South San Francisco/San Bruno Local Limits 1/22/2009

CONSTITUENT	mg/L	ug/L
ARSENIC (As)	0.74	740
CADMIUM (Cd)	0.25	250
CHROMIUM (Cr)	2.43	2430
COPPER (Cu)	1.12	1120
LEAD (Pb)	0.79	790
MERCURY (Hg)	0.01	10
NICKEL (Ni)	0.90	900
SELENIUM (Se)	15.07	15070
SILVER (Ag)	1.40	1400
ZINC (Zn)	2.00	2000
CYANIDE (CN)	0.32	320
PHENOLICS	19.37	19370
PCB's (Polychlorinated Biphenyls)	0.01	10
CHLORINATED PESTICIDES	0.01	10
PAH's (Polynuclear Aromatic Hydrocarbons)	8.13	8130
SULFIDES (S)	1.0	1000
AMMONIA (NH ₃)	90.14	90140
BENZENE	0.13	130
CHLOROFORM (*With Interim credit)	0.04-(0.11*)	40-(110*)
DICHLOROBENZENE (1,2)	0.01	10
DICHLOROBENZENE (1,4)	0.10	100
DICHLOROETHENE (1,2)	0.28	280
ETHYLBENZENE	1.59	1590
METHYLENE CHLORIDE	0.29	290
NAPHTHALENE	2.49	2490
TETRACHLOROETHENE (PERC)	0.53	530
TOLUENE	1.35	1350
TRICHLOROETHANE (TCA)	1.55	1550
TRICHLOROETHYLENE (TCE)	0.08	80
XYLENE	1.32	1320
pH (Lower Limit)	5.0	
pH (Upper Limit)	12.0	
FLASHPOINT (Degrees Fahrenheit, Minium, Closed-cup)	140	

Local Limits to be applied as Daily Maximum Limits