



**DROP MANHOLE SECTION**

**NOTES:**

1. DROP CONNECTION SHALL BE USED WHERE ELEVATION DIFFERENCE BETWEEN INLET AND OUTLET INVERTS IS 18" OR GREATER.
2. ALL PIPING SHALL BE PVC OR HDPE.
3. DROP CONNECTION SHALL BE ENCASED IN CONCRETE 6" MIN AROUND DROP PIPE.
4. WATERSTOPS SHALL BE A-LOK, KORE-N-SEAL, OR APPROVED EQUAL. GROUT AROUND WATERSTOP.
5. INLETS SHALL BE FLUSH WITH MANHOLE INSIDE WALL.